



CERTIFICATE

KEMA No.: 2100895.01

Issued to:

Applicant:

ATRAL-SECAL GmbH
Johannes Gutenberg Straße 7
65719, HOFHEIM-WALLAU, Germany

Manufacturer/Licensee:

ATRAL-SECAL GmbH
Johannes Gutenberg Straße 7
65719, HOFHEIM-WALLAU, Germany

Products : Smog alarm detecting unit
Trade name : HAGER
Type/model : TG501*



The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60950-1:2001;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2100895

KEMA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: February 21, 2007 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.

P. Nabuurs
Managing director

G.H. Wensink
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Products : Smog alarm detecting unit
Trade name : HAGER
Type : TG501*
Rated voltage : 230 V
Nature of supply : ac
Rated frequency : 50 Hz
Rated current : 30 mA
Class : II
Operating temperature : max. 55°C

TESTS

Test requirements

EN 60950-1:2001

Test result

The test results are laid down in KEMA test file 2100895.01.

Remarks

This report is based on the VDE certificate 40018418 with report 2339700-3240-0002/78469, dated 2006-08-23.

TG501*, * indicates a certain colour.

The part list is included in the mentioned report.

Conclusion

The examination proved that all test requirements were met.

Tested by : E.J.M. Nijhuis

Checked by : G.H. Wensink

Factory-Locations

ATRAL-SECAL GmbH,
Johannes Gutenberg Straße 7, 65719, HOFHEIM-WALLAU, Germany